

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

**0809 - CPR - 1253**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction products

### **Fire protective boards for load bearing steel structures**

PAROC FPS 17, PAROC FPS 17t, PAROC FPS 17a and PAROC FPS 17ta fire protective stone wool boards for fire protection of structural steel columns and beams in resistance to fire classes R 30 - R 240 as specified in ETA 08/0093

placed on the market under the name or trade mark of

**Paroc Group**  
P.O. Box 240  
FI-00181 Helsinki

and produced in the manufacturing plants

**Paroc Oy Ab**, FI-21600 Parainen  
**Paroc AB**, SE-53304 Hällekis  
**UAB Paroc**, Savanoriu 124, LT-03153 Vilnius  
**Paroc Polska Sp. z o.o.**, Ul. Gnieznienska 4, PL-62-240 Trzemeszno.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the

**ETA 08/0093**  
issued on 23/04/2018

and

**EAD 350142-00-1106**  
September 2017

under system 1 for the performance set out in the ETA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

### **constancy of performance of the construction products.**

This certificate was first issued on May 18, 2018 and will remain valid as long as neither the ETA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The validity of the certificate may be confirmed at the web address [www.VTTcertificate.com](http://www.VTTcertificate.com).

Espoo May 18, 2018



Tiina Ala-Outinen  
Business Manager



Heli Välimäki  
Senior Expert